SEIKO


QUARTZ

Cal. 7126A

Cal. 7126A







Cal. 7126A

Characteristics

Casing diameter:

 26.0×23.7 mm

Maximum height:

3.8 mm without battery

Jewels:

Frequency of quartz crystal oscillator: 32,768 Hz (Hz=Hertz..... Cycles per second)

Driving system : Step motor (2 poles) Regulation system: Trimmer condenser

Train wheel setting Calendar (Day and date)

Time differential adjusting device: Pull the crown out to the first click and the hour hand move one hour every click.

Instant setting device for day and date calendar.

Battery life indicator: Second hand moves in two-second interval.

PART NO.	PART NAME	PART NO.	PART NAME
131 115	Third wheel bridge	4259 009	Anti-magnetic shield plate
165 001	Hour corrector lever	4270 024	Battery connection
167 001	Time corrector setting wheel	011 542	Upper hole jewel for step rotor
168 003	Intermediate wheel for time	011 542	Lower hole jewel for step rotor
	correction (C)	012 152	Third wheel bridge screw
168 004	Intermediate wheel for hour	012 152	Circuit block screw
	correction (D)	012 152	Coil block screw
168 007	Intermediate wheel for time	012 153	Day finger screw
	correction (G)	012 154	Screw for rocking bar holder
231 029	Third wheel & pinion	012 154	Lower end piece screw for third wheel
241 060	Fourth wheel & pinion	012 713	Hour wheel guard screw
261 019	Minute wheel	012 789	Setting lever spring screw
270 037	Center minute wheel with cannon	013 975	Eccentric dial pin
	pinion	017 135	Tube for coil block (A) Tube for coil block (B)
271 056	Hour wheel	017 136	Tube for circuit block
282 023	Clutch wheel	017 137	Tube for yoke
354 078	Winding stem	017 260	Tube for yoke Tube for third wheel bridge (B)
376 001	Hour wheel guard	017 261	Tube for setting lever spring
383 049	Setting lever	017 262	Tube for hour wheel guard (A)
384 022	Yoke (Clutch lever)	017 263	Tube for hour wheel guard (B)
388 922 391 018	Setting lever spring Train wheel setting lever	017 264	Tube for hour wheel guard (C)
436 004	Lower end-piece for third wheel	017 265	Tube for third wheel bridge (A)
464 001	Rocking bar holder	017 266	Tube for third wheel bridge (C)
☆ 470 170	Day star with dial disk	017 268	Tube for rocking bar holder
495 003	Spacer for third wheel bridge	017 379	Tube for date jumper screw
556 013	Date finger	A Maxell SR1130SW	t dad for date jumper as an
560 004	Friction spring for fourth wheel &	☆SEIKO SR1130SW	Silver oxide battery
300 00-	pinion	SEIKO SB-AU	
701 007	Fifth wheel & pinion	MAGEING SENG 7	
☆801 103 }	•		
☆801 104	Date dial		
802 022	Date driving wheel		
803 006	Rocking bar		
808 035	Date dial guard (A)		
808 036	Date dial guard (B)		
810 012	Date jumper	H	
817 015	Intermediate date wheel		
868 012	Day finger		
☆884 128	Holding ring for dial		
963 007	Snap for day star with dial disk		
4001 173	Circuit block		
4002 010	Coil block		
4146 007	Step rotor		
4219 012	Insulator for battery connection		
4239 018	Rotor stator	1	

Cal. 7126A

Remarks:

Day star with dial disk

Date dial

\$801 103(Black figures on white background) } Used when both the crown and the calendar frame \$801 104(White figures on black background) } used when both the crown and the calendar frame are located at 3 o'clock position.

If any other type of date dial is required, specify ① Cal. No. ② Jewels ③ The crown position ④ The calendar frame position and ⑤ Dial No.

Holding ring for dial

★884 128······The type of holding ring for dial is determined based on design of cases and dials. If the shape of holding ring for dial is different from the photograph, check the case number and refer to "SEIKO Quartz Casing Parts List" to choose a corresponding holding ring for dial.

Battery

☆ Maxell SR1130SW

☆SEIKO SR1130SW

⇔ SEIKO SB-AU

The substitutive battery might be added to the applied battery in the future. In that case, please refer to separate "BATTERY LIST FOR SEIKO QUARTZ


WATCHES".

Note that SEIKO battery is marked with "SEIZAIKEN" on its (+) side.

TECHNICAL GUIDE



CAL. 7126A




CONTENTS

l.	SPECIFICATIONS 1
H.	STRUCTURE OF THE CIRCUIT BLOCK
Ш.	TIME DIFFERENTIAL ADJUSTING DEVICE 2
IV.	DISASSEMBLING, REASSEMBLING AND LUBRICATING 3
	1. Indicating mechanism
	2. Electronic circuit 5
	3. Gear train and setting mechanism
V.	CHECKING AND ADJUSTMENT 7
	Check output signal
	Check battery voltage
	Check battery conductivity
	Check circuit block conductivity
	• Check coil block
	Check reset and train wheel setting conditions
	• Check accuracy 8
	Check current consumption

I. SPECIFICATIONS

Cal. No.	7126A	
Time indication	3 hands	
Additional mechanism	Day and date Time differential adjusting device Train wheel setting device Electronic circuit reset switch Battery life indicator	
Loss/gain	Loss/gain at normal temperature range Monthly rate: less than 15 seconds (Annual rate: less than 3 minutes)	
Casing diameter	φ26.0 mm	
Height	3.8 mm without battery	
Regulation system	Trimmer condenser	
Measuring gate by Quartz Tester	Any gate is available.	
Battery	Maxell SR1130SW or SEIKO (SEIZAIKEN) SR1130SW or SB-AU Battery life is approximately 5 years. Voltage 1,55V	
- Jewels	2 jewels	


II. STRUCTURE OF THE CIRCUIT BLOCK



III. TIME DIFFERENTIAL ADJUSTING DEVICE

Cal. 7126A is provided with the time differential adjusting device which can advance or delay the time by an hour by turning the crown without stop moving.


in this device, as shown in the illustration below, the hour corrector lever moves when the crown is pulled out to the first click and the intermediate wheel for time correction C gears with the intermediate wheel for time correction G. Since the intermediate wheel for time correction G engages with the hour wheel, the hour hand can be advanced or delayed by an hour by turning the crown one click clockwise or counterclockwise.




The relation between hour wheel and time corrector setting wheel

n i trans de la companya de la comp

Hour wheel and time corrector setting wheel normally move together. When adjusting time difference, time corrector setting wheel revolves by one cog (one hour) by intermediate wheel for time correction and after revolving, hour wheel is regulated by hour jumper.



IV. DISASSEMBLING, REASSEMBLING AND LUBRICATING



on a final de la California de La Califo


Remarks for disassembling and reassembling

1 Hour, minute, second hands


After reassembling the hands, pull out the crown to the first click and check to see if the hour hand moves by an hour when adjusting time difference. At this time, be sure to check if the hands go around without touching the "SEIKO" mark and "SQ" mark.

(13) Rocking bar

Set the rocking bar as shown in the illustration on the right, the notch to the protrustion of the setting lever and the pin on the tip of rocking bar to the groove of the hour corrector lever respectively.



(4) (5) (9) Intermediate wheel for time correction C, G, and Intermediate wheel for hour correction D. When reassembling them, set them with their beveled side up on the hour corrector lever.



(7) (18) Hour wheel and time corrector setting wheel When normal disessembling and reassembling, be sure to handle them together.


If disassembling and reassembling are needed, follow the procedures below.

How to disassemble


Put the checking stick in the clearance between the hour wheel and the time corrector setting wheel and widen the clearance little by little. After that, put the checking stick in the holes (three places) on the hour wheel and push the time corrector setting wheel to remove it from the hour wheel.

• How to reassemble


After putting the hour wheel on the time corrector setting wheel, put the executing stick in the holes on the hour wheel and putting out the hour jumper to engage it with the hour wheel.



2. Electronic circuit



3. Gear train and setting mechanism



V. CHECKING AND ADJUSTMENT

• Refer to the "SEIKO QUARTZ TECHNICAL GUIDE, GENERAL INSTRUCTION" for analogue watches for details

Procedur	98
CHECK OUTPUT SIGNAL	Result: One-second blinking : Normal No one-second blinking: Defective
CHECK BATTERY VOLTAGE	Result: More than 1.5V: Normal Less than 1.5V: Defective
CHECK BATTERY CONDUCTIVITY	
CHECK CIRCUIT BLOCK CONDUCTIVITY	
CHECK COIL BLOCK	Result: $2.0 \text{K}\Omega \sim 4.0 \text{K}\Omega \colon \text{Normal}$ Less than $2.0 \text{K}\Omega$ (Short circuit) $\text{More than } 4.0 \text{K}\Omega$ (Broken wire) $\text{Replace the coil block}$ with a new one.
CHECK RESET AND TRAIN WHEEL SETTING CONDITI	ONS
1. Check to see if the second hand stops immediately when the grown is pulled out to the third click and if it starts promptly after one second when the grown is pushed back to the normal position.	Result: Stops completely and starts moving after one second: Does not stop or move irregularly: Defective
Check for the clearance between the reset portion of the train wheel setting lever and the reset pin. (Check after the circuit block is removed.) Re	Train wheel setting level sett

Procedures

1 With the crown at the nomal, first, and the second click position



Result:

Located at the outer circumference of the circle of the main plate: Normal

Circle of the main plate



Located at the center of the circle of the main plate: Defective

* Replace the train wheel setting lever.

(2) With the crown at the third click position



Located at the center of the circle of the main plate: Normal




Located at the outer circumference of the circle of the main plate: Defective

*Replace the train wheel setting lever.

- 3. Check to see if there is a clearance between the reset portion of train wheel satting lever and the fourth wheel and pinion.
 - (1) With the crown at the normal position, the first click and the second click position.

With the crown at the third click position



Clearance: Normal

No clearance: Defective

Replace the train wheel

setting lever.

No clearance: Normal


Clearance: Defective

Replace the train wheel

setting lever.

CHECK ACCURACY

CHECK CURRENT CONSUMPTION



Regult:

Less than 2.QuA : Normal More than 2.QuA: Defective

Check the electronic circuit.

All procedures of Disease ribling, recessmilling, Checking and Adjustment are completed.